

§115 - Schedule A
Sewer Use Law
Town of Moreau
Saratoga County, NY

Substance	Maximum Concentration of Discharge Allowed (mg/l)
1,1,1-Trichloroethane	1
Ammonia	40
Antimony	10
Arsenic	0.25
Benzene	0.1
BOD5	240
Boron	5
Bromine, Iodine, Chlorine	75
Cadmium	0.212
Calcium	500
Chloroform	1
Chromium, total	0.4
Copper	0.208
Cyanide, total	0.33
Ethylbenzene	0.1
Fluoride	17.4
Iron	5
Lead	0.39
Manganese	5
Mercury	0.0002
Methylene chloride	1
Napthalene	1
Nickel	0.198
Oil & grease	50
pH (range)	6.0 - 9.0 S.U.
Phenols	5
Silver	0.2
Tetrachloroethylene	0.046
Toluene	0.1
Total Suspended Solids	300
Trichloroethylene	0.094
Xylene	0.1
Zinc	1.5
Zirconium	10